

February 22, 2006

SIM / TECH FILTER
KOTESKEY BROTHERS EXCAVATING INC.
GARY KOTESKEY
06598 HORTON BAY N RD.
BOYNE CITY MI 49712

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: SIM / TECH FILTER
Product Name: GAG SIM/TECH FILTER
Model Number(s): STF-100, STF-100A, STF-100A2 AND STF-100A3
Product File No: 20060020

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2011.

This approval supersedes the approval issued on March 29, 2001, under product file number 20010148.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010148.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The sizing calculations of the pressure distribution network must include 0.5 head loss for this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov